

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

## PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

### DETAILS OF THE CONTRACTOR

(\*Where applicable)

Registration No: 602665000 Branch No\*: 000  
 Trading Title: BD MANAGEMENT SERVICES  
 Address: The Cube, Yew Tree Avenue, Dagenham, Greater London  
 Postcode: RM10 7FN Tel No: 020 8215 3000

### DETAILS OF THE CLIENT

Contractor Reference Number (CRN): N/A  
 Name: London Borough of Barking & Dagenham  
 Address: London Borough of Barking & Dagenham, Town Hall, 1 Town Square, Barking, Essex  
 Postcode: IG11 7LU Tel No: 0208 215 3000

### DETAILS OF THE INSTALLATION

Occupier: N/A  
 UPRN: N/A  
 Address: Laburnum House, Dagenham  
 Postcode: RM10 7AF Tel No: N/A

## PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required:

Satisfactory report issued after completion of remedial works highlighted on previous report 31417949

Date(s) when inspection and testing was carried out: ( 11/06/2025 ) Records available (651.1): ( ✓ ) Previous inspection report available (651.1): ( ✓ ) Previous report date: ( 04/03/2025 )

## PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

**Description of premises** Dwelling: ( N/A ) Commercial: ( ✓ ) Industrial: ( N/A ) Other (include brief description): N/A  
 Estimated age of electrical installation: ( 30 ) years Evidence of additions or alterations: ( ✓ if Yes, estimated age 1 years ) Overall assessment of the installation for continued use: **Satisfactory/Unsatisfactory\*\*** (delete as appropriate)  
 General condition of the installation (in terms of electrical safety): The installation compromises of circuits supplying the landlords services and communal areas

\*\*An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified (listed in PART 5 of this report) and it is recommended that these are acted upon as a matter of urgency.





This certificate is not valid if the serial number has been defaced or altered

31808176

EICR18EICR18.2-3C

Original to the person ordering the work

PART 4 : DECLARATION

INSPECTION AND TESTING

I/We, being the person responsible for the inspection and testing of the electrical installation (as indicated by my/our signature below), particulars of which are described in PART 6, having exercised reasonable skill and care when

RICHARD EVERETT Signature: [Signature] Date: 11/06/2025

I/We further RECOMMEND, subject to the necessary remedial action being taken, that the installation is inspected and tested by: 04/03/2030 (date)

As per GN3

The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

Name (capitals) on behalf of the contractor identified in PART 1: RICHARD EVERETT Signature: [Signature] Date: 11/06/2025

carrying out the inspection and testing, hereby declare that the information in this report, including the observations (PART 5) and the attached Schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in PART 6 of this report.

Name (capitals) on behalf of the contractor identified in PART 1 :

Give reason for recommendation:

REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE CONTRACTOR

This report is based on the model forms shown in Appendix 6 of (as amended) Enter ✓ or value in the respective fields, as appropriate. Where an item is not applicable insert N/A

@ Copyright Certsure LLP (August 2024)

Please see the 'Notes for Recipients'

ELECTRICAL INSTALLATION  
CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 5 : OBSERVATIONS





This certificate is not valid if the serial number has been defaced or altered

31808176

EICR18EICR18.2-3C

## ELECTRICAL INSTALLATION CONDITION REPORT 3C

**APPROVED  
CONTRACTOR**

One of the following Codes, as appropriate, has been allocated to each of the observations made below to indicate to the person(s) responsible for the electrical installation the degree of urgency for remedial action:

**Code C1 Danger Present**  
Risk of injury. Immediate remedial action required

**Code C2 Potentially Dangerous** Urgent remedial action required

Code C3  
Improvement Recommended

**Code FI**  
**Further Investigation Required**

Referring to the **Schedule of Items Inspected** (see PART 9), the attached **Schedule of Circuit Details and Test Results** (see PART 11A & 11B), and subject to any **agreed limitations** listed in PART 6 –

No remedial action is required ( ~~.....~~ ), OR      The following observations are made:

[illegible]

Immediate remedial action required for items: ( N/A )

**Urgent remedial action required for items:** ( N/A )

Improvement recommended for items: ( 1,2,3,4 )

Further investigation required for items: ( N/A )

Additional pages? (None) State page numbers: (N/A)

Please see the 'Guidance for recipients on the classification codes'



PART 6 : DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671: 2018, as amended to .....  
of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the electrical installation covered by this report: Test and inspection of Laburnum House, landlords areas only..... (see additional page No. N/A )

Agreed limitations including the reasons, if any, on the inspection and testing (653.2): Only 20% of accessories were removed during the test.....

Agreed with (print name): LBD HEC.....

Extent of sampling: 10% of circuits tested to confirm the test result readings recorded on previous EICR..... (see additional page No. N/A )

Operational limitations including the reasons: Cannot verify main fuses at head due to seal. Circuits within lift shaft not tested..... (see additional page No. N/A )

N/A (date). Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric

PART 7 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

<b>System type and earthing arrangements</b>  TN-S: ( ) <u>N/A</u> ..... TT: ( )..... IT: ( ).....  <b>Supply protective device</b>  BS EN: ( <u>LIM</u> ..... ) Type: ( <u>N/A</u> ..... ) Rated current: ( <u>LIM</u> ..... ) A	<b>Number and type of live conductors</b>  AC 1-phase, 2-wire: ( <u>N/A</u> ..... ) 3-phase, 3-wire: ( <u>N/A</u> ..... )  DC 2-wire: ( <u>N/A</u> ..... ) 3-wire: ( <u>N/A</u> ..... ) Confirmation of supply polarity: Other sources of supply (Schedule of Test Results)	2-phase, 3-wire: ( <u>N/A</u> ..... ) 3-phase, 4-wire: (..... ) Other: ( <u>N/A</u> ..... ) Page No: ( <u>N/A</u> ..... )	<b>Nature of supply parameters</b>  Nominal voltage between lines, $U$ <sup>[1]</sup> : Nominal line voltage to Earth, $U_o$ <sup>[1]</sup> : ( <u>N/A</u> ..... ) V Nominal frequency, $f$ <sup>[1]</sup> : ( <u>230</u> ..... ) V Prospective fault current, $I_{pf}$ <sup>[2]*</sup> : ( <u>50</u> ..... ) Hz ( <u>3.71</u> ..... ) kA External earth fault loop impedance, $Z_e$ <sup>[2]*</sup> : ( <u>0.04</u> ..... ) $\Omega$
--	--	--	---

PART 8 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT



## ELECTRICAL INSTALLATION CONDITION REPORT

Maximum demand (load): ( <u>200</u> ) kVA/AXX (delete as appropriate)	<b>Main protective conductors</b>	<b>Main protective bonding connections</b>	<b>Earthing</b>	<b>Main switch / Switch-fuse / Circuit-breaker / RCD</b>
<b>Means of Earthing</b>	conductor: Water installation pipes:	Gas installation pipes:		Location: (Mains intake ground floor )
Distributor's facility: ( <u>N/A</u> )	(material <u>Copper</u> )	Connection/continuity	✓	BS EN: (60947-3...) Type: ( <u>3</u> ) Rating / setting of device: ( <u>200</u> ) A
Installation earth electrode(s): ( <u>N/A</u> )	csa ( <u>35</u> ) mm <sup>2</sup>	Oil installation pipes:	✓	No. of poles: ( <u>N/A</u> ) Current rating: ( <u>200</u> ) A Voltage rating: ( <u>400</u> ) V
Earth electrode type – rod(s), tape, etc: ( <u>None</u> )	..... Structural steel: .....	Lightning protection:	N/A	<b>Where an RCD is used as the main switch</b>
Location: ( <u>N/A</u> )	Main protective bonding conductors:	Other (state):	N/A	RCD rated residual operating current, $I_{\Delta n}$ : ( ) mA RCD Type: ( <u>AC</u> )
Electrode resistance to Earth: ( <u>N/A</u> ) Ω	(material <u>Copper</u> )	verified: ( <u>N/A</u> )	N/A	Rated time delay: ( ) ms Measured operating time: ( <u>N/A</u> ) ms
	csa ( <u>16</u> ) mm <sup>2</sup>	Connection/continuity	N/A	
	verified: ( <u>N/A</u> )		( )	
			( )	
			( )	
			( <u>N/A</u> )	
			( <u>N/A</u> )	

\*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current,  $I_{pf}$ , and external earth fault loop impedance,  $Z_e$ , must be recorded.

**All fields must be completed.** Enter either, as appropriate: ' ' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists, or Code appropriately: CODE 'C1,' 'C2,' 'C3' or 'FI' (codes to be recorded in PART 5, with additional comments (where appropriate) on attached numbered sheets)



## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with *BS 7671: 2018* (as amended) – Requirements for Electrical Installations

**PART 9 : SCHEDULE OF ITEMS INSPECTED** (enter , N/A or Classification Code C1, C2, C3 or FI, as applicable)

Original  
to the person ordering the work



# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018

## 1.0 Intake equipment (visual inspection only)

An outcome against an item in section 1.1, other than access to live parts, should not be used to

- Accessibility of all protective bonding connections (543.3.2) ( ) 4.16 Confirmation that integral test button / switch, where present, causes AFDD to trip when operated (643.10)
- Provision of earthing / bonding labels at all appropriate locations (514.13.1) ( )

(N/A) determine the overall assessment of the installation. Where inadequacies are identified, a cross 3.2 FELV - requirements satisfied (411.7) ( ) 4.17 Presence of diagrams, charts or schedules at or near equipment,

this report. where required (514.9.1) ( ) ) should be put against the appropriate item and a comment made in Part 5 of

### 1.1 Distributor / supplier intake equipment

### 3.3 Other methods of protection

4.18 Presence of alternative supply warning notice at or near N/A

• Service cable ( ) Where any of the methods listed below are employed, details should be provided on separate sheets where required (514.15) ( )

• Service head ( ) • Non-conducting location (418.1) (N/A) 4.19 Presence of next inspection recommendation label,

• Earthing arrangement ( ) • Earth-free local equipotential bonding (418.2) (N/A) where required (514.12.1) ( )

• Meter tails ( ) • Electrical separation (413; 418.3) (N/A) 4.20 Presence of other required labelling (please specify) (514) (N/A) • Metering equipment ( )

• Double insulation (412) (N/A) 4.21 Compatibility of protective devices, bases and other components;

• Isolator, where present ( ) • Reinforced insulation (412) Provisions where automatic disconnection of supply is not feasible (419) ((N/A) correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (432; 433; 434) ( )

Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and / or dutyholder must be informed. 4.0 Distribution equipment, including consumer units and distribution boards 4.22 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) ( ) It is strongly recommended that the person ordering the work informs the appropriate authority.

mechanical damage where cables enter equipment

4.1 Adequacy of working space / accessibility to equipment (132.12; 513.1) ( ) 4.23 Protection against

1.2 Consumer's isolator, where present ( ) 4.2 Security of fixing (134.1.1) ( ) (522.8.1; 522.8.5; 522.8.11) ( )

1.3 Consumer's meter tails ( ) 4.3 Condition of insulation of live parts (416.1) ( ) 4.24 Protection against electromagnetic effects where cables enter

2.0 Presence of adequate arrangements for parallel or switched alternative sources 4.4 Adequacy security of barriers or enclosures (416.2.3) ( ) ferromagnetic enclosures (521.5.1) ( )



**ELECTRICAL INSTALLATION CONDITION REPORT**

Issued in accordance with

2.1	A dequate arrangements where a generating set operates as a switched connections, including connections to alternative to the public supply (551.6) correctly located in terminals and are tight and secure (526.1)	( )	4.5	Condition of enclosure(s) in terms of IP rating, etc. (416.2)	( )	4.25	Confirmation that ALL conductor busbars, are
2.2	A dequate arrangements where a generating set operates in parallel public supply (551.7)	(N/A)	4.6	Condition of enclosure(s) in terms of fire rating, etc. (421.1.201; 421.1.6; 526.5)	( )	5.0	Distribution circuits with the
3.0	Methods of protection		4.7	Enclosure not damaged / deteriorated so as to impair safety (651.2)	( )	5.1	Identification of conductors (514.3)
			4.8	Presence and effectiveness of obstacles (417.2)	(N/A)	5.2	C ables correctly supported throughout their run (521.10.202; 522.8.5)
			4.9	P resence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	(N/A)	5.3	Condition of insulation of live parts (416.1)
3.1	Automatic disconnection of supply (ADS)		4.10	Operation of main switch(es) (functional check) (643.10)	( )	5.4	N on-sheathed cables protected by enclosure in conduit,
	• Main earthing / bonding arrangement (411.3; Chap. 54)	( )	4.11	Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10)	( )		trunking (521.10.1)
	• Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or	( )	4.12	Confirmation that integral test button / switch causes RCD(s) to trip			presence of installation earth electrode arrangement (542.1.2.3)
	• Adequacy of earthing conductor size (542.3; 543.1.1)	( )		when operated (functional check) (643.10)	( )		(including flexible conduit) (522)
	• Adequacy of earthing conductor connections (542.3.2)	( )	4.13	RCD(s) provided for fault protection - includes RCBOs		5.6	C ables correctly terminated in enclosures (526)
	• Accessibility of earthing conductor connections (543.3.2)	( )		(411.4.204; 411.4.5; 411.5.2; 531.2)	( )	5.7	E xamination of cables for signs of unacceptable thermal or
	• Adequacy of main protective bonding conductor sizes (544.1.1)	( )	4.14	RCD(s) provided for additional protection / requirements, where required -			damage / deterioration (421.1; 522.6)
	• Adequacy and location of main protective bonding conductor connections (544.1.2)	( )		includes RCBOs (411.3.3; 415.1)	( )	5.8	A dequacy of cables for current-carrying capacity with regard for the type
		( )	4.15	P resence of RCD six-monthly test notice, where required (514.12.2)	( )		and nature of installation (523)

(as amended) – Requirements for Electrical Installations



## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with *BS 7671: 2018*

**PART 9 : SCHEDULE OF ITEMS INSPECTED** (enter , N/A or Classification Code C1, C2, C3 or FI, as applicable)



## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with

5.9 Adequacy of protective devices; type and rated current for fault protection (411.3) ( )	6.2 Cables correctly supported throughout their run (521.10.202; 522.8.5) ( )	• *For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203) ( ) N/A
5.10 Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1) ( )	6.3 Condition of insulation of live parts (416.1) ( )	• *For final circuits supplying luminaires within domestic (household) premises (411.3.4) ( )
5.11 Coordination between conductors and overload protective devices (433.1; 533.2.1) ( )	6.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1) ( )	* Older installations designed prior to BS 7671: 2018 may not have required RCDs for additional protection.
5.12 Cable installation methods / practices with regard to the type and nature of installation and external influences (522) ( )	6.5 Suitability of containment systems for continued use (including flexible conduit) (522) ( )	6.14 Provision of fire barriers, sealing arrangements and protection against thermal effects (527) ( )
5.13 Where exposed to direct sunlight, cable of a suitable type (522.11.1) ( )	6.6 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (523) ( )	6.15 Band II cables segregated / separated from Band I cables (528.1) ( )
5.14 Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) –	6.7 Adequacy of protective devices; type and rated current for fault protection (411.3) ( )	6.16 Cables segregated / separated from non-electrical services (528.3) ( )
• Installed in prescribed zones (see Section D. <i>Extent and limitations</i> ) (522.6.202) ( )	6.8 Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1) ( )	6.17 Termination of cables at enclosures - identify / record numbers and locations of items inspected (526) –
• Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204) ( )	6.9 Coordination between conductors and overload protective devices (433.1; 533.2.1) ( )	• Connection under no undue strain (526.6) ( )
5.15 Provision of fire barriers, sealing arrangements and protection against thermal effects (527) ( )	6.10 Wiring system(s) appropriate for the type and nature of the installation and external influences (522) ( )	• No basic insulation of a conductor visible outside enclosure (526.8) ( )
5.16 Band I and II cables segregated / separated from Band I cables (528.1) ( )	6.11 Where exposed to direct sunlight, cable of a suitable type (522.11.1) ( )	• Connections of live conductors adequately enclosed (526.5) ( )
5.17 Cables segregated / separated from non-electrical services (528.3) ( )	6.12 Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) –	• Adequately connected at point of entry to enclosure (glands, bushes, etc.) (522.8.5) ( )
5.18 Condition of circuit accessories (651.2) ( )	• Installed in prescribed zones (see Section D. <i>Extent and limitations</i> ) (522.6.202) ( )	6.18 Condition of accessories including socket-outlets, switches and joint boxes (651.2) ( )
5.19 Suitability of circuit accessories for external influences (512.2) ( )	• Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204) ( )	6.19 Suitability of accessories for external influences (512.2) ( )
5.20 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) ( )	6.13 Provision of additional protection by RCD having rated residual operating current not exceeding 30 mA –	6.20 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) ( )
5.21 Adequacy of connections, including CPCs, within accessories and to fixed and stationary equipment - identify / record numbers and locations of items inspected (526) ( )	• *For all socket-outlets of rating 32 A or less (411.3.3) ( )	<b>7.0 Isolation and switching</b>
		7.1 Isolators –



# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018

5.22 Presence, operation and correct location of appropriate devices for isolation and switching (Chap. 46; 537)	( )	<p><i>Additional protection by RCD may not have been provided as a noted exception in certain non-domestic installations covered by indent (ii) of Regulation 411.3.3.</i></p> <ul style="list-style-type: none"> <li>*For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3) ( )</li> <li>*For cables concealed in walls at a depth of less than 50 mm (522.6.202) ( )</li> </ul>	<ul style="list-style-type: none"> <li>• Presence and condition of appropriate devices (462; 537.2) ( )</li> <li>• Acceptable location - state if local or remote from equipment in question (462; 537.2.7) ( )</li> <li>• Capable of being secured in the OFF position (462.3) ( )</li> <li>• Correct operation verified (643.10) ( )</li> <li>• Clearly identified by position and / or durable marking (537.2.7) ( )</li> <li>• Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2) ( )</li> </ul>
5.23 General condition of wiring system (651.2)	( )		
5.24 Temperature rating of cable insulation (522.1.1; Table 52.1)	( )		
<b>6.0 Final circuits</b>			
6.1 Identification of conductors (514.3)	( )		

Original (to the person ordering the work)

BS 7671: 2018 (as amended) – Requirements for Electrical Installations



## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with

### PART 9 : SCHEDULE OF ITEMS INSPECTED (enter , N/A or Classification Code C1, C2, C3 or FI, as applicable)

7.2 Switching off for mechanical maintenance –	8.5 Security of fixing (134.1.1)	( ) • Low voltage (e.g. 230 volt) socket-outlets sited at least 2.5 m from
• Presence and condition of appropriate devices (464.1; 537.3.2)	( )	8.6 Cable entry holes in ceiling above luminaires, sized or sealed so as to zone 1 (701.512.3) (N/A)
• Capable of being secured in the OFF position where not under continuous supervision (464.2)	( )	• Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2) (N/A)
• Correct operation verified (643.10)	( )	8.7 Recessed luminaires (downlighters) – N/A
(701.512.3) (N/A)	• Clearly identified by position and / or durable marking (537.3.2.4)	( ) • Suitability of accessories and controlgear etc. for a particular zone
7.3 Emergency switching off – location (701.55)	• Installed to minimise build-up of heat by use of “fire rated” fittings,	N/A • Suitability of current-using equipment for particular position within the
• Presence and condition of appropriate devices (465; 537.3.3; 537.4) locations –	(N/A)	insulation displacement box or similar (421.1.2) (N/A)
• Readily accessible for operation where danger might occur (537.3.3.6)	(N/A)	• No signs of overheating to surrounding building fabric (559.4.1) No signs of overheating to conductors / terminations
(526.1) (N/A)	N/A	(N/A)
• Correct operation verified (643.10)	(N/A)	•
• Clearly identified by position and / or durable marking	(N/A)	9.0 Special locations and installations
(537.3.3.5; 537.3.3.6; 537.4.3; 537.4.4)	(N/A)	Where special installations or locations relating to a particular Section of Part 7, an additional inspection
7.4 Functional switching –	Schedule(s) should be provided on separate pages.	( )
• Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	( )	9.1 Location(s) containing a bath or shower – ( )
• Correct operation verified (643.10)	( )	• Additional protection by RCD having rated residual operating current not exceeding 30 mA for all low voltage (LV) circuits serving the location or passing through zones 1 and / or 2 of the location (701.411.3.3) (N/A)
8.0 Current-using equipment (permanently connected) covered by the		10.0 Prosumer’s low voltage installation (N/A)
		Where elements of a prosuming installation falling within the scope of Chapter 82 are



## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018

- 8.1** Condition of equipment in terms of IP rating, etc. (416.2; 422.3; 422.4; 522.4) ( ) met (701.414.4.5) ( N/A )
- Where used as a protective measure, requirements for SELV or PELV report, additional schedules detailing the associated inspection and testing should be provided on separate pages.
- 8.2** Equipment does not constitute a fire hazard (421) ( ) • Shaver supply units complying with BS EN 61558-2-5 formerly BS 3535
- 8.3** Enclosure not damaged / deteriorated so as to impair safety (701.512.3) ( N/A ) Name (capitals): RICHARD EVERETT
- (134.1.1; 416.2) ( ) • Presence of supplementary bonding conductors, unless not required Signature: Date: 11/06/2025
- 8.4** Suitability for the environment and external influences (512.2) ( ) by BS 7671: 2018 (701.415.2) ( N/A )

### PART 10 : SCHEDULES AND ADDITIONAL PAGES (the pages identified are an essential part of this report (see Regulation 653.2))

Schedule of Results for the	InspectionsSchedule of Circuit Details and Test Additional pages, including data sheets Special installations or locations Schedules relating to Prosumer's Continuation sheets
4, 5 & 6	installation for additional sources (indicated in item 9.2 above) installations (indicated in item 10 above)
Page No(s): ( )	Page No(s): ( 7 & 8 ) Page No(s): ( None ) Page No(s): ( None ) Page No(s): ( None ) Page No(s): ( None )





This certificate is not valid if the serial number has been defaced or altered

31808176

EICR18EICR18.2-3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018

(as amended) – Requirements for Electrical Installations

Original to the person ordering the work

PART 11A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part 11B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)





This certificate is not valid if the serial number has been defaced or altered

CONTINUATION SHEET : EIC and EICR

31808176

ISN18EIC18.2-  
3c

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

Circuit conductor

Overcurrent protective device

RCD

This schedule is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

Enter a ✓ or value in the respective fields, as appropriate. Where an item is not applicable insert N/A



# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018

Circuit number	Circuit description	Type of wiring (see footer to PART 11B)	Reference method (BS 7671)	Number of points served	(number & csa)		Max. disconnection time (BS 7671) (s)									
					Live (mm <sup>2</sup> )	CPC (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short circuit capacity (kA)	Maximum permitted Z <sub>s</sub> * (Ω)	BS (EN)	Type	Rating (A)	Operating current, I <sub>dn</sub> (mA)
1L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L1	Roof DB	D	B	1	16	Trunk	5	88-2	gG	60	80	N/A	N/A	N/A	N/A	N/A
6L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L2	Lift motor room DB's	F	C	2	16	16	5	88-2	gG	60	80	N/A	N/A	N/A	N/A	N/A
6L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

## DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

\*\*SPD Type.

Where combined T1 + T2 or T2 + T3

DB designation: Main DB  
device is installed, indicate by ticking both Location of DB: Mains intake ground floor Type

brackets. ....

Z<sub>db</sub>: 0.03 (Ω) ✓  
protect sensitive equipment, enter I<sub>pf</sub> at DB: 8.1 (kA) ✓

Where T3 devices are installed on a circuit to

Confirmation of supply polarity: ( ) Phase sequence confirmed: ( ) details in 'Comments' (PART 11B),

## TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: N/A

### Overcurrent protective device for the distribution circuit

BS (EN): ( N/A ) Type: ( N/A ) Nominal voltage: ( N/A ) V Rating: ( N/A ) A  
No. of phases: ( N/A )





This certificate is not valid if the serial number has been defaced or altered

**CONTINU**  
Issued in accordance with BS 7671:

31808176	EICR18EICR18.2-3C	31808176	ISN18EIC18.2-3c
----------	-------------------	----------	-----------------

**SPD Details\*\*** Types: T1 ( N/A ) T2 ( N/A ) T3 ( N/A ) N/A ( ) (See Section 534 for further details).  
Note that not all SPDs have visible  
Status indicator checked (where functionality indicator is present): ( N/A ) functionality indication.

**Associated RCD (if any)**  
BS (EN): ( N/A ) RCD Type: ( N/A ) I<sub>Δn</sub>: ( N/A ) mA No. of poles: ( N/A )  
Operating time: ( N/A ) ms

BS 7671: 2018 (as amended) Enter a ( ) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A  
N/A.....  
(as amended) – Requirements for Electrical Installations

**PART 11B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into ‘Schedule of Circuit Details’ in Part 11A)**

Original  
to the person ordering the work



ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018

Circuit number	Continuity (Ω)					Insulation resistance			Polarity  (✓)	Max. measured earth fault loop impedance Z <sub>s</sub> (Ω)	RCD		AFDD**	Comments and additional information, where required	
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC			Operating time*	Test button  (✓)	AFDD test button  (✓)		
	(Line) r <sub>1</sub>	(Neutral) r <sub>n</sub>	(cpc) r <sub>2</sub>	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>2</sub>	(MΩ)	(MΩ)	(V)			(ms)				
1L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5L1	N/A	N/A	N/A	0.06	N/A	N/A	>200	500		0.09	N/A	N/A	N/A	N/A	
6L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
1L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5L2	N/A	N/A	N/A	0.08	N/A	N/A	>200	500		0.11	N/A	N/A	N/A	N/A	
6L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
1L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
6L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Circuits/equipment vulnerable to damage when testing (where applicable):  
.....  
N/A

TESTED BY Name (capitals): RICHARD EVERETT ..... Position: ..... QS ..... Signature: .....  
..... Date: 11/06/2025 .....

..... (ER SERIAL NUMBER AGAINST IDENT USED)  
..... EACH INSTRUMENTED ..... Insulation resistance:  
Multi-function: ..... Continuity: ..... N/A ..... Earth fault loop impedance: ..... Earth electrode resistance: ..... RCD: .....  
1008123102183666 ..... N/A ..... N/A .....  
..... N/A ..... N/A .....





This certificate is not valid if the serial number has been defaced or altered

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

31808176

ISN18EIC18.2-3c

Original (to the person ordering the work)

\* RCD effectiveness is verified using an alternating current test at rated residual operating current ( $I_{\Delta n}$ )  
'Comments and additional information, where required' column.

\*\* Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state):-N/A.....
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	-------------------------

Enter (✓) (X) or value in the respective fields, as appropriate  
Where an item is not applicable insert N/A

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

This schedule is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A



ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018

Circuit number	Circuit description	Type of wiring see footer to PART B	Reference method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short circuit capacity (kA)	Maximum permitted Z <sub>s</sub> * (Ω)	BS (EN)	Type	Rating (A)	Operating current, I <sub>Δn</sub> (mA)
1L1	CCTV	B	B	1	2.5	2.5	0.4	61009	B	16	10	2.73	61009	A	16	30
1L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L1	Door entry and riser sockets	B	B	17	2.5	2.5	0.4	60898	B	16	10	2.73	N/A	N/A	N/A	N/A
2L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

**DISTRIBUTION BOARD (DB) DETAILS (complete in every case)**

DB designation: DB5

Z<sub>db</sub>: 0.06 (Ω)

Confirmation of supply polarity: ( ) Phase sequence confirmed: ( )

Where combined T1 + T2 or T2 + T3

Mains intake ground floor Type brackets.

Where T3 devices are installed on a circuit to

details in 'Comments' (PART B),

**TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION**

Supply to DB is from: RG DB1 - 5L1

**Overcurrent protective device for the distribution circuit**





This certificate is not valid if the serial number has been defaced or altered

CONTINUATION SHEET : EIC and EICR

31808176

ISN18EIC18.2-3c

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

<p>SPD Details** Types: T1 ( N/A ) T2 ( N/A ) T3 ( N/A ) N/A ( ) (See Section 534 for further details). Note that not all SPDs have visible</p> <p>N/A</p> <p>Status indicator checked (where functionality indicator is present): ( ) functionality indication.</p>	<p>BS (EN): ( 60898 ) Type: ( C ) Nominal voltage: ( 230 ) V Rating: ( 63 ) A No. of phases: ( 1 )</p> <p><b>Associated RCD (if any)</b></p> <p>BS (EN): ( N/A ) RCD Type: ( N/A ) I<sub>Δn</sub>: ( N/A ) mA No. of poles: ( N/A )</p> <p>Operating time: ( N/A ) ms</p>
--	---

This schedule is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A





This certificate is not valid if the serial number has been defaced or altered

## CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

31808176

ISN18EIC18.2-  
3c

APPROVED  
CONTRACTOR

### PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity ( $\Omega$ )					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance ( $\Omega$ )	RCD		AFDD**	Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC			Operating time*	Test button (✓)	AFDD test button (✓)	
	(Line) $r_1$	(Neutral) $r_n$	(cpc) $r_2$	( $R_1 + R_2$ )	$R_2$	(M $\Omega$ )	(M $\Omega$ )	(V)			(ms)			
1L1	N/A	N/A	N/A	0.20	N/A	N/A	>200	500	✓	0.26	28.7	✓	N/A	N/A
1L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L1	N/A	N/A	N/A	0.52	N/A	N/A	>200	500	✓	0.58	N/A	N/A	N/A	N/A
2L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Circuits/equipment vulnerable to damage when testing (where applicable):

N/A

TESTED BY Name (capitals): RICHARD EVERETT

Position: QS

Signature:

Date: 11/06/2025



<b>ENTER SERIAL NUMBER AGAINST IDENT USED)</b>			
<b>EACH INSTRUMENT USED)</b>		Insulation resistance:	
Multi-function: 1008123102183666	Continuity: N/A	N/A	Earth fault loop impedance: N/A
		Earth electrode resistance: N/A	RCD: N/A

\* RCD effectiveness is verified using an alternating current test at rated residual operating current ( $I_{\Delta n}$ )

\*\* Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the

‘Comments and additional information, where required’ column.

## PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B ‘Schedule of Test Results’ to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footnotes to Part B)	Reference method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short circuit capacity (kA)	Maximum permitted Zs* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I <sub>Δn</sub> (mA)
1L1	Main entrance lights	D	B	5	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
1L2	Outside west side lights	B	B	2	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
1L3	Caretakers lights	D	B	13	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
2L1	Rear entrance lights	D	B	6	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
2L2	Bin room lights	D	B	14	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
2L3	Meter room lights	D	B	17	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
3L1	Outside north lights	D	B	7	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
3L2	Ground floor intake lights	D	B	4	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
3L3	1st - 3rd west lights	D	B	12	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
4L1	Fire alarm panel	O	B	1	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
4L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L1	DB5	D	D	5	25	25	5	60898	C	63	10	0.35	N/A	N/A	N/A	N/A

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------





This certificate is not valid if the serial number has been defaced or altered

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

31808176

ISN18EIC18.2-3c

5L2	DB5	D	D	5	25	25	5	60898	C	63	10	0.35	N/A	N/A	N/A	N/A
5L3	DB5	D	D	5	25	25	5	60898	C	63	10	0.35	N/A	N/A	N/A	N/A
6L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

**DISTRIBUTION BOARD (DB) DETAILS (complete in every case)**

DB designation: RG DB1  
device is installed, indicate by ticking both Location of  
  
Z<sub>db</sub>: 0.05 (Ω) ✓ I<sub>pf</sub> at DB+: 3.7 (kA) ✓  
protect sensitive equipment, enter ✓  
Confirmation of supply polarity: ( ) Phase sequence confirmed: ( ) ✓  
SPD Details\*\* Types: T1 ( N/A ) T2 ( N/A ) T3 ( N/A ) N/A ( )  
Status indicator checked (where functionality indicator is present): ( ) functionality indication.

\*\*SPD Type.  
Where combined T1 + T2 or T2 + T3  
DB: Mains intake ground floor Type brackets.  
Where T3 devices are installed on a circuit to  
details in 'Comments' (PART B),  
(See Section 534 for further details).  
Note that not all SPDs have visible  
N/A

**TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION**

Supply to DB is from: N/A  
  
Overcurrent protective device for the distribution circuit  
BS (EN): ( N/A ) Type: ( N/A ) Nominal voltage: ( N/A ) V Rating: ( N/A ) A  
No. of phases: ( N/A )  
Associated RCD (if any)  
BS (EN): ( N/A ) RCD Type: ( N/A ) I<sub>Δn</sub>: ( N/A ) mA No. of poles: ( N/A )  
Operating time: ( N/A ) ms

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into ‘Schedule of Circuit Details’ in Part A)															
Circuit number	Continuity (Ω)					Insulation resistance			Polarity  (✓)	Max. measured earth fault loop impedance  (Ω)	RCD		AFDD**	Comments and additional information, where required	
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live  (MΩ)	Live / Earth  (MΩ)	Test voltage DC  (V)			Operating time*  (ms)	Test button  (✓)	AFDD test button  (✓)		
	(Line) r <sub>1</sub>	(Neutral) r <sub>n</sub>	(cpc) r <sub>2</sub>	(R <sub>1</sub> + R <sub>2</sub> ) R <sub>s</sub>	R <sub>2</sub>										
RCD effectiveness is verified using an alternating current test at rated residual operating current (I <sub>Δn</sub> )	N/A	N/A	N/A	0.47	N/A	N/A	>200	500	✓	0.52	N/A	** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit	N/A		

Original (to the person ordering the work)





This certificate is not valid if the serial number has been defaced or altered

## CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

31808176

ISN18EIC18.2-  
3c

### APPROVED CONTRACTOR

1L2	N/A	N/A	N/A	0.84	N/A	N/A	>200	500	✓	0.89	N/A	N/A	N/A	N/A
1L3	N/A	N/A	N/A	0.73	N/A	N/A	>200	500	✓	0.78	N/A	N/A	N/A	N/A
2L1	N/A	N/A	N/A	1.06	N/A	N/A	>200	500	✓	1.12	N/A	N/A	N/A	N/A
2L2	N/A	N/A	N/A	1.15	N/A	N/A	>200	500	✗	1.30	N/A	N/A	N/A	N/A
2L3	N/A	N/A	N/A	1.99	N/A	N/A	>200	500	✗	2.04	N/A	N/A	N/A	N/A
3L1	N/A	N/A	N/A	1.20	N/A	N/A	>200	500	✗	1.25	N/A	N/A	N/A	N/A
3L2	N/A	N/A	N/A	0.45	N/A	N/A	>200	500	✗	0.50	N/A	N/A	N/A	N/A
3L3	N/A	N/A	N/A	0.65	N/A	N/A	>200	500	✗	0.70	N/A	N/A	N/A	N/A
4L1	N/A	N/A	N/A	Lim	N/A	N/A	Lim	N/A	✗	Lim	N/A	N/A	N/A	N/A
4L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L1	N/A	N/A	N/A	0.01	N/A	>200	>200	500	✗	0.06	N/A	N/A	N/A	N/A
5L2	N/A	N/A	N/A	0.01	N/A	>200	>200	500	✗	0.06	N/A	N/A	N/A	N/A
5L3	N/A	N/A	N/A	0.01	N/A	>200	>200	500	✓	0.06	N/A	N/A	N/A	N/A
6L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Circuits/equipment vulnerable to damage when testing (where applicable):

N/A

TESTED BY Name (capital): RICHARD EVERETT

Position: QS

Signature:

Date: 11/06/2025

### TESTED AGAINST (SERIAL NUMBER AGAINST IDENT USED)

#### EACH INSTRUMENT

Insulation resistance:

Multi-function:

Continuity:

N/A

Earth fault loop impedance:

Earth electrode resistance:

RCD:

1008123102183666

N/A

N/A

N/A

N/A

## PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

This schedule is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A





This certificate is not valid if the serial number has been defaced or altered

## CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

31808176

ISN18EIC18.2-  
3c

APPROVED  
CONTRACTOR

Circuit number	Circuit description	Type of wiring see footnote PART B	Reference method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live  (mm <sup>2</sup> )	cpc  (mm <sup>2</sup> )		BS (EN)	Type	Rating  (A)	Short circuit capacity  (kA)	Maximum permitted Zs*  (Ω)	BS (EN)	Type	Rating  (A)	Operating current, I <sub>Δn</sub>  (mA)
7L1	4th - 7th floor west lights	D	B	16	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
7L2	Store room lights east	D	B	3	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
7L3	1st - 3rd east lights	D	B	12	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
8L1	Outside east side lights	D	B	5	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
8L2	4th - 7th east lights	D	B	16	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
8L3	Photocell	D	B	1	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
9L1	South staircase lights	D	B	17	1.5	1.5	0.4	60898	B	10	10	4.37	N/A	N/A	N/A	N/A
9L2	1st - 7th dry riser and north stairs	D	B	15	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
9L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10L1	DB2	D	D	5	25	25	5	60898	C	63	10	0.35	N/A	N/A	N/A	N/A
10L2	DB2	D	D	5	25	25	5	60898	C	63	10	0.35	N/A	N/A	N/A	N/A
10L3	DB2 (this way used only)	D	D	5	25	25	5	60898	C	63	10	0.35	N/A	N/A	N/A	N/A
11L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\* RCD effectiveness is verified using an alternating current test at rated residual operating current (I<sub>Δn</sub>)

\*\* Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)  
© Copyright Certsure LLP (August 2024)

For an EIC, enter a                    or value in the respective fields, as appropriate.  
For an EICR, enter                    ,                    or value in the respective fields, as appropriate

Page 26 of 24

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking (✓) (X)	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): F.P.....
--------------------------	---	--	--	---	--	--------------------------------	--------------------------------	------------------------------	-------------------------

Where an item is not applicable insert N/A





This certificate is not valid if the serial number has been defaced or altered

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

31808176

ISN18EIC18.2-3c

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: RG DB1

Z<sub>db</sub>: 0.05 (Ω) I<sub>pf</sub> at DB+: 3.7 (kA)

Confirmation of supply polarity: ( ) Phase sequence confirmed: ( )

SPD Details\*\* Types: T1 ( N/A ) T2 ( N/A ) T3 ( N/A ) N/A ( )

Status indicator checked (where functionality indicator is present): ( ) functionality indication.

\*\*SPD Type.  
Where combined T1 + T2 or T2 + T3  
DB: Mains intake ground floor Type brackets.

Where T3 devices are installed on a circuit to  
details in 'Comments' (PART B),  
(See Section 534 for further details).  
Note that not all SPDs have visible

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: N/A

Overcurrent protective device for the distribution circuit

BS (EN): ( N/A ) Type: ( N/A ) Nominal voltage: ( N/A ) V Rating: ( N/A ) A  
No. of phases: ( N/A )

Associated RCD (if any)

BS (EN): ( N/A ) RCD Type: ( N/A ) I<sub>Δn</sub>: ( N/A ) mA No. of poles: ( N/A )  
Operating time: ( N/A ) ms

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Original (to the person ordering the work)





This certificate is not valid if the serial number has been defaced or altered

## CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

31808176

ISN18EIC18.2-  
3c

APPROVED  
CONTRACTOR

Circuit number	Continuity ( $\Omega$ )					Insulation resistance			Polarity  (✓)	Max. measured earth fault loop impedance $Z_s$  ( $\Omega$ )	RCD		AFDD**	Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC  (V)			Operating time*  (ms)	Test button  (✓)	AFDD test button  (✓)	
	(Line) $r_1$	(Neutral) $r_n$	(cpc) $r_2$	( $R_1 + R_2$ )	$R_2$									
7L1	N/A	N/A	N/A	2.05	N/A	N/A	>200	500	✓	2.10	N/A	N/A	N/A	N/A
7L2	N/A	N/A	N/A	0.85	N/A	N/A	>200	500	✓	0.90	N/A	N/A	N/A	N/A
7L3	N/A	N/A	N/A	0.83	N/A	N/A	>200	500	✓	0.88	N/A	N/A	N/A	N/A
8L1	N/A	N/A	N/A	1.69	N/A	N/A	>200	500	✗	1.74	N/A	N/A	N/A	N/A
8L2	N/A	N/A	N/A	2.15	N/A	N/A	>200	500	✗	2.20	N/A	N/A	N/A	N/A
8L3	N/A	N/A	N/A	0.46	N/A	N/A	>200	500	✗	0.51	N/A	N/A	N/A	N/A
9L1	N/A	N/A	N/A	1.93	N/A	N/A	>200	500	✗	1.98	N/A	N/A	N/A	N/A
9L2	N/A	N/A	N/A	1.85	N/A	N/A	>200	500	✗	1.90	N/A	N/A	N/A	N/A
9L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10L3	N/A	N/A	N/A	0.02	N/A	N/A	>200	500	✗	0.07	N/A	N/A	N/A	N/A
11L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Circuits/equipment vulnerable to damage when testing (where applicable):

N/A

TESTED BY Name (capital): RICHARD EVERETT Position: QS Signature:

\* RCD effectiveness is verified using an alternating current test at rated residual operating current ( $I_{\Delta n}$ ) Date: 11/06/2025

\*\* Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)  
© Copyright Certsure LLP (August 2024)

For an EIC, enter a or value in the respective fields, as appropriate.  
For an EICR, enter , or value in the respective fields, as appropriate

Page 28 of 24

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking (✓) (X)	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): F.P.
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	---------------------

Where an item is not applicable insert N/A





This certificate is not valid if the serial number has been defaced or altered

CONTINUATION SHEET : EIC and EICR

31808176

ISN18EIC18.2-3c

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

Multi-function:		Continuity:		Insulation resistance:		Earth fault loop impedance:		Earth electrode resistance:		RCD:	
1008123102183666		N/A		N/A		N/A		N/A		N/A	



**PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)**

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Zs* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I <sub>Δn</sub> (mA)
1L1	8th floor lights	B	B	10	1.5	1.5	0.4	60898	C	10	10	2.19				
1L2	Smoke alarm panel 8th - 16th	O	B	9	1.5	1.5	0.4	60898	C	16	10	1.37				
1L3	Spare															
2L1	9th - 12th west side lights	B	B	12	1.5	1.5	0.4	60898	C	10	10	2.19				
2L2	Smoke alarm panel ground - 7th	O	B	8	1.5	1.5	0.4	60898	C	16	10	1.37				
2L3	Spare															
3L1	9th - 16th east lights	B	B	12	1.5	1.5	0.4	60898	C	10	10	2.19				
3L2	Spare															
3L3	Spare															
4L1	12th - 16th west lights	B	B	16	1.5	1.5	0.4	60898	C	10	10	2.19				
4L2	Spare															
4L3	Spare															
5L1	12th - 16th east lights	B	B	16	1.5	1.5	0.4	60898	C	10	10	2.19				
5L2	Spare															
5L3	Spare															
6L1	8th - 16th north staircase lights	B	B	16	1.5	1.5	0.4	60898	C	10	10	2.19				
6L2	Spare															
6L3	Spare															

**DISTRIBUTION BOARD (DB) DETAILS (complete in every case)**

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (where recommended).

DB designation: RG DB2  
Location of DB: 8th floor intake

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables in metal conduit	(B) Thermoplastic cables in metal conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metal trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): F.P.
SPD Details	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*\*SPD Type.

(where combined T1 + T2 or T2 + T3 or T1 + T2 + T3)

device is installed, indicate by ticking boxes

Type brackets.

Where T2 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 5.4.4 for further details).

Note that not all SPDs have visible

**TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION**

For an EIC, enter a or value in the respective fields, as appropriate.

Supply to DB is from the respective fields, as appropriate.

RG DB1 - 10.3

Associated RCD (if any)

BS (EN) 60898

Type: (Cables) Nominal voltage: 230 V Rating: 63 A No. of poles: (N/A) Operating time: (N/A) ms

RCD Type: (N/A) BS (EN) 60898

BS (EN) 60898

BS (EN) 60898

BS (EN) 60898





This certificate is not valid if the serial number has been defaced or altered

CONTINUATION SHEET : EIC and EICR

31808176

ISN18EIC18.2-  
3c

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations





This certificate is not valid if the serial number has been defaced or altered

31808176

ISN18EIC18.2-3c

CONTINUATION

## SHEET : EIC and EICR

Issued in accordance with *BS 7671: 2018* (as amended) – Requirements for Electrical Installations

Original (to the person ordering the work)

### PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

This schedule is based on the model forms shown in Appendix 6 of *BS 7671: 2018* (as amended)

@ Copyright Certsure LLP (August 2024)

Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A

+ Where applicable. \*Where figure is not taken from *BS 7671*, state source: N/A

Page 32 of 24





This certificate is not valid if the serial number has been defaced or altered

31808176	ISN18EIC18.2-3c
----------	-----------------

CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

					Circuit conductor		Overcurrent protective device		RCD
--	--	--	--	--	-------------------	--	-------------------------------	--	-----

This schedule is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A



**CONTINUATION**

## SHEET : EIC and EICR

Issued in accordance with *BS 7671: 2018* (as amended) – Requirements for Electrical Installations

Circuit number	Circuit description	Type of wiring see footer to Part B	Reference method (BS 7671)	Number of points served	(number & csa)		Max. disconnection time (BS 7671)  (s)									
					Live  (mm <sup>2</sup> )	cpc  (mm <sup>2</sup> )		BS (EN)	Type	Rating  (A)	Short circuit capacity  (kA)	Maximum permitted Zs*  (Ω)	BS (EN)	Type	Rating  (A)	Operating current, I <sub>Δn</sub>  (mA)
7L1	Contactors	D	B	2	1.5	1.5	0.4	60898	C	10	10	2.19				
7L2	Spare															
7L3	Spare															
8L1	Spare															
8L2	Spare															
8L3	Spare															
* RCD effectiveness is verified using an alternating current test at rated residual operating current (I <sub>Δn</sub> )						** Where installed.	Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit									

This certificate is based on the model forms shown in Appendix 6 of *BS 7671: 2018* (as amended)  
 @ Copyright Certsure LLP (August 2024)

For an EIC, enter a  or value in the respective fields, as appropriate.

For an EICR, enter , or value in the respective fields, as appropriate

Page 34 of 24

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking (✓) (X)	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): F.P.

Where an item is not applicable insert N/A



CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

<b>DISTRIBUTION BOARD (DB) DETAILS (complete in every case)</b>																
<b>**SPD Type.</b>																
DB designation: RG DB2																
Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Location of DB: 8th floor intake Type																
brackets.																
Z <sub>db</sub> : 0.07 (Ω) I <sub>pf</sub> at DB+: 3.42 (kA)																
Where T3 devices are installed on a circuit to protect sensitive equipment, enter																
Confirmation of supply polarity: ( ) Phase sequence confirmed: (NA)																
SPD Details** Types: T1 ( N/A ) T2 ( N/A ) T3 ( N/A ) N/A ( ) details in 'Comments' (PART B), (See Section 534 for further details). Note that not all SPDs have visible																
Status indicator checked (where functionality indicator is present): ( ) functionality indication. N/A																
<b>TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION</b>																
Supply to DB is from: RG DB1 - 10L3																
<b>Overcurrent protective device for the distribution circuit</b>																
BS (EN): ( 60898 ) Type: ( C ) Nominal voltage: ( 230 ) V Rating: ( 63 ) A No. of phases: ( 1 )																
<b>Associated RCD (if any)</b>																
BS (EN): ( N/A ) RCD Type: ( N/A ) I <sub>Δn</sub> : ( N/A ) mA No. of poles: ( N/A )																
Operating time: ( N/A ) ms																





This certificate is not valid if the serial number has been defaced or altered

31808176

**ISN18EIC18.2-**

3c

**CONTINUATION**

## SHEET : EIC and EICR

Issued in accordance with *BS 7671: 2018* (as amended) – Requirements for Electrical Installations

**PART B : SCHEDULE OF TEST RESULTS** (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

[illegible]

Circuits/equipment vulnerable to damage when testing (where applicable): N/A


This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

For an EIC, enter a  or value in the respective fields, as appropriate.

@ Copyright Certsure LLP (August 2024)

For an EICR, enter \_\_\_\_\_, \_\_\_\_\_ or value in the respective fields, as appropriate

Page	36	of	24
------	----	----	----

TESTED BY CODES for Type of wiring	RICHARD EVERETT							Signature: 	Date: 11/06/2025
	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables		
1008123102183666	Continuity:			Insulation resistance:	Earth fault loop impedance:		Earth electrode resistance:	RCD:	
	N/A			N/A	Where an item is not applicable, insert N/A		N/A	N/A	

**Original** (to the person ordering the work)





This certificate is not valid if the serial number has been defaced or altered

31808176

ISN18EIC18.2-3c

CONTINUATION

## SHEET : EIC and EICR

Issued in accordance with *BS 7671: 2018* (as amended) – Requirements for Electrical Installations

Original (to the person ordering the work)

### PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

This schedule is based on the model forms shown in Appendix 6 of *BS 7671: 2018* (as amended)

@ Copyright Certsure LLP (August 2024)

Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A

+ Where applicable. \*Where figure is not taken from *BS 7671*, state source: N/A

Page 37 of 24



CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

Circuit number	Circuit description	Type of wiring see footer to Part B	Reference to BS (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short circuit capacity (kA)	Maximum permitted Zs* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I <sub>Δn</sub> (mA)
1	TV supply	B	B	1	2.5	2.5	0.4	60898	C	16	10	1.37	N/A	N/A	N/A	N/A
2	Radio supply	B	B	4	2.5	2.5	0.4	60898	C	16	10	1.37	N/A	N/A	N/A	N/A
3	Roof generator	B	B	1	2.5	2.5	0.4	60898	C	16	10	1.37	N/A	N/A	N/A	N/A
4	CCTV	B	B	1	2.5	2.5	0.4	60898	C	16	10	1.37	N/A	N/A	N/A	N/A
5	Lift motor room lights RHS	B	B	4	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
6	Lift motor room lights LHS	B	B	3	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
7	Tank room lights	B	B	3	1.5	1.5	0.4	60898	C	10	10	2.19	N/A	N/A	N/A	N/A
8	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\* RCD effectiveness is verified using an alternating current test at rated residual operating current (I<sub>Δn</sub>)

\*\* Where installed. Note, not all AEDDs have a test function. Where a circuit contains an AEDD this should be stated in the field for that circuit

in the 'Comments and additional information, where required' column.

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

@ Copyright Certsure LLP (August 2024)

For an EIC, enter a or value in the respective fields, as appropriate.

For an EICR, enter , or value in the respective fields, as appropriate

Page 38 of 24

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking (✓) (X)	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): F.P.....
--------------------------	---	--	--	---	--	--------------------------------	--------------------------------	------------------------------	-------------------------

Where an item is not applicable insert N/A



# CONTINUATION

## SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)		TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION	
<b>DB designation:</b> Roof DB device is installed, indicate by ticking both Location of DB: Lift motor room Type		Supply to DB is from: Main DB - 5L1	
<b>Where combined T1 + T2 or T2 + T3</b> Where T3 devices are installed on a circuit to details in 'Comments' (PART B), Note that not all SPDs have visible		<b>Overcurrent protective device for the distribution circuit</b> BS (EN): ( 88-2 ) Type: ( gG ) Nominal voltage: ( 230 ) V Rating: ( 60 ) A No. of phases: ( 1 )	
<b>SPD Details**</b> Types: T1 ( N/A ) T2 ( N/A ) T3 ( N/A ) N/A ( ) Status indicator checked (where functionality indicator is present): ( ) functionality indication.		<b>Associated RCD (if any)</b> BS (EN): ( N/A ) RCD Type: ( N/A ) $I_{\Delta n}$ : ( N/A ) mA No. of poles: ( N/A ) Operating time: ( N/A ) ms	



CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

Original  
(to the person ordering the work)

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity ( $\Omega$ )					Insulation resistance			Polarity  (✓)	Max. measured earth fault loop impedance  ( $\Omega$ )	RCD		AFDD**	Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC  (V)			Operating time*  (ms)	Test button  (✓)	AFDD test button  (✓)	
	(Line) $r_1$	(Neutral) $r_n$	(cpc) $r_2$	( $R_1 + R_2$ )	$R_2$								(M $\Omega$ )	
1	N/A	N/A	N/A	0.03	N/A	N/A	>200	500	✓	0.12	N/A	N/A	N/A	N/A
2	N/A	N/A	N/A	0.11	N/A	N/A	>200	500	✓	0.20	N/A	N/A	N/A	N/A
3	N/A	N/A	N/A	Lim	N/A	N/A	Lim	N/A	LIM	Lim	N/A	N/A	N/A	N/A
4	N/A	N/A	N/A	Lim	N/A	N/A	Lim	N/A	LIM	Lim	N/A	N/A	N/A	N/A
5	N/A	N/A	N/A	0.41	N/A	N/A	>200	500	✓	0.50	N/A	N/A	N/A	N/A
6	N/A	N/A	N/A	0.46	N/A	N/A	>200	500	✓	0.55	N/A	N/A	N/A	N/A
7	N/A	N/A	N/A	0.51	N/A	N/A	>200	500	✓	0.60	N/A	N/A	N/A	N/A
8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
* RCD effectiveness is verified using an alternating current test at rated residual operating current ( $I_{\Delta n}$ )														
** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.														

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

@ Copyright Certsure LLP (August 2024)

For an EIC, enter a or value in the respective fields, as appropriate.

For an EICR, enter , or value in the respective fields, as appropriate

Page 40 of 24

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking (✓) (X)	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A.....
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	-------------------------

Where an item is not applicable insert N/A





This certificate is not valid if the serial number has been defaced or altered

31808176

ISN18EIC18.2-3c

CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations


Circuits/equipment vulnerable to damage when testing (where applicable):

N/A

TESTED BY Name (capital): RICHARD EVERETT Position: QS Signature:

 Date: 11/06/2025

TESTED BY (ENTER SERIAL NUMBER AGAINST INSTRUMENT USED)					
Multi-function:	Continuity:	Insulation resistance:	Earth fault loop impedance:	Earth electrode resistance:	RCD:
1008123102183666	N/A	N/A	N/A	N/A	N/A



**CONTINUATION**

## SHEET : EIC and EICR

Issued in accordance with *BS 7671: 2018* (as amended) – Requirements for Electrical Installations

**PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)**

[illegible]

~~@ Copyright Certsure LLP (August 2024)~~

**DISTRIBUTION BOARD (DB) DETAILS (complete in every case)**

\*\*SPD Type.

For an EICR, enter \_\_\_\_\_, \_\_\_\_\_ or value in the respective fields, as appropriate

**TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION**

Page 42 of 24

Distribution Board (DB) DETAILS (Complete in every case)										To be completed only if the DB is not connected directly to the origin of the installation
CODES for Type of wiring	(A) Thermoplastic	(B) Thermoplastic	(C) Thermoplastic	(D) Thermoplastic	(E) Thermoplastic	(F) Thermoplastic + SWA	(G) Thermosetting / SWA	(H) Mineral-insulated	Other (state):	N/A
	Unsheathed cables	Cables in metallic conduit	Cables in non-metallic conduit	Cables in metallic type brackets	Cables in non-metallic type brackets	Cables	Cables	Cables		
0.09	(0)	1 at DB1	2.05	(kA)	Where T3 devices are installed on a circuit	Overcurrent protective device for the distribution circuit				

Confirmation of supply polarity: (.....) ✓ Phase sequence confirmed: (.....) NA





This certificate is not valid if the serial number has been defaced or altered

31808176	ISN18EIC18.2-3c
----------	-----------------

CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations



CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to Part B)	Reference method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live	cpc		BS (EN)	Type	Rating (A)	Short circuit capacity (kA)	Maximum permitted Zs* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I <sub>Δn</sub> (mA)
					(mm <sup>2</sup> )	(mm <sup>2</sup> )										
1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4	Windcrest	B	B	1	1.5	1.5	0.4	60898	B	6	10	7.28	N/A	N/A	N/A	N/A
5	Car lights	B	B	1	1.5	1.5	0.4	60898	B	6	10	7.28	N/A	N/A	N/A	N/A
6	Shaft lights	B	B	1	1.5	1.5	0.4	60898	B	6	10	7.28	N/A	N/A	N/A	N/A
7	CCTV	B	B	1	2.5	1.5	0.4	60898	B	16	10	2.73	N/A	N/A	N/A	N/A
8	Lift motor room RCD socket	B	B	1	2.5	2.5	0.4	60898	B	16	10	2.73	N/A	N/A	N/A	N/A
9	Lift motor room heater	B	B	1	2.5	2.5	0.4	60898	B	16	10	2.73	N/A	N/A	N/A	N/A
* RCD effectiveness is verified using an alternating current test at rated residual operating current (I <sub>Δn</sub> )								** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.								

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking (✓) (X)	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A.....
--------------------------	---	--	--	---	--	--------------------------------	--------------------------------	------------------------------	-------------------------



CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations


<b>DISTRIBUTION BOARD (DB) DETAILS (complete in every case)</b>		<b>TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION</b>	
DB designation: Even's DB device is installed, indicate by ticking both Location of DB: Lift motor room Type		Supply to DB is from: Main DB - 5L1	
Z <sub>db</sub> : 0.09 (Ω) I <sub>pf</sub> at DB+: 2.47 (kA)		Overcurrent protective device for the distribution circuit	
Confirmation of supply polarity: ( ) Phase sequence confirmed: (NA)		BS (EN): ( 88-2 ) Type: ( gG ) Nominal voltage: ( 230 ) V Rating: ( 60 ) A No. of phases: ( 1 )	
SPD Details** Types: T1 ( N/A ) T2 ( N/A ) T3 ( N/A ) N/A ( )		Associated RCD (if any)	
Status indicator checked (where functionality indicator is present): ( ) functionality indication.		BS (EN): ( N/A ) RCD Type: ( N/A ) I <sub>Δn</sub> : ( N/A ) mA No. of poles: ( N/A )	
		Operating time: ( N/A ) ms	



CONTINUATION

SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

Original  
(to the person ordering the work)

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity ( $\Omega$ )					Insulation resistance			Polarity  (✓)	Max. measured earth fault loop impedance $Z_s$  ( $\Omega$ )	RCD		AFDD**	Comments and additional information, where required	
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live  (M $\Omega$ )	Live / Earth  (M $\Omega$ )	Test voltage DC  (V)			Operating time*  (ms)	Test button  (✓)	AFDD test button  (✓)		
	(Line) $r_1$	(Neutral) $r_n$	(cpc) $r_2$	( $R_1 + R_2$ )	$R_2$										
1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4	N/A	N/A	N/A	Lim	N/A	N/A	Lim	N/A	LIM	Lim	N/A	N/A	N/A	N/A	
5	N/A	N/A	N/A	Lim	N/A	N/A	Lim	N/A	LIM	Lim	N/A	N/A	N/A	N/A	
6	N/A	N/A	N/A	Lim	N/A	N/A	Lim	N/A	LIM	Lim	N/A	N/A	N/A	N/A	
7	N/A	N/A	N/A	Lim	N/A	N/A	Lim	N/A	LIM	Lim	N/A	N/A	N/A	N/A	
8	N/A	N/A	N/A	0.01	N/A	N/A	>200	500	✗	0.10	27.8	✓	N/A	N/A	
9	N/A	N/A	N/A	0.10	N/A	N/A	>200	500	✓	0.19	N/A	N/A	N/A	N/A	
* RCD effectiveness is verified using an alternating current test at rated residual operating current ( $I_{\Delta n}$ )											** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column				

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

@ Copyright Certsure LLP (August 2024)

For an EIC, enter a            or value in the respective fields, as appropriate.

For an EICR, enter            ,            or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Page

46 of 24

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking (✓) (X)	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A.....
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	-------------------------







Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice.

For further information about electrical safety and how NICEIC can help you, visit:

**www.niceic.com**

*\* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).*

## **GUIDANCE FOR RECIPIENTS ON THE CLASSIFICATION CODES ONLY ONE CLASSIFICATION CODE SHOULD BE GIVEN FOR EACH RECORDED OBSERVATION**

@ Copyright Certsure LLP (August 2024)

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, this should be identified in PART 7 Supply Characteristics and Earthing Arrangements, and the Schedules of Circuit Details and Schedule of Test Results (PARTS 11A & 11B) compiled accordingly.

PART 6 (Details and limitations) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in PART 6. It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration should have been given by the inspector in PART 4 of the report. The declaration must reflect the statement given in PART 3, which summarises the observations and recommendations made in PART 5. Where one or more observations have been made in PART 5, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation as code C1 (danger present) the safety of those using the installation is at risk. Wherever practicable, items classified as C1 should be made safe on discovery, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation as code C2 (potentially dangerous) the safety of those using the installation may be at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated that an item requires further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where inadequacies in the intake equipment have been observed (Item 1 of PART 9), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

### **Classification code C1 (Danger present)**

Where an observation has been given a Classification code C1, the safety of those using the installation is at risk and immediate remedial action is required.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the danger. The NICEIC contractor issuing this report will be able to provide further advice.

NICEIC makes available 'Electrical Danger Notification' forms to enable inspectors to record, and then to communicate to the person ordering the report, any dangerous condition discovered.

### **Classification code C2 (Potentially dangerous)**

Classification code C2 indicates that, whilst those using the installation may not be at immediate risk, urgent remedial action is required to remove potential danger. The NICEIC contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given for the next inspection date in PART 4 of this report is conditional upon all items which have been given a Classification code C1 and code C2 being remedied immediately and as a matter of urgency, respectively.

It would not be reasonable for the inspector to indicate that the installation is in a satisfactory condition if any observation in this report has been given a code C1 or code C2 classification.

### **Classification code C3 (Improvement recommended)**

Where an observation has been given a Classification code C3, the inspection and/or testing has revealed a noncompliance with the current safety standard which, whilst not presenting immediate or potential danger, would result in a significant safety improvement if remedied. Careful consideration should be given to the safety benefits of improving these aspects of the installation. The NICEIC contractor issuing this report will be able to provide further advice.



@ Copyright Certsure LLP (August 2024)

**Code FI (Further investigation required without delay)**

It should usually be possible for the inspector to attribute a Classification code to each observation without indicating a need for further investigation.

However, where 'FI' has been entered against an observation the inspector considers that further investigation of that observation is likely to reveal danger or potential danger that, due to the agreed extent or limitations of the inspection and/or testing (entered in PART 6), could not be fully identified at the time.

It would not be appropriate for the inspector to indicate that the installation is in a satisfactory condition if there is reasonable doubt as to whether danger or potential danger exists. Consequently, where the inspector has indicated 'Further investigation required without delay' (FI) the overall assessment of the installation (PART 3) should be marked as 'Unsatisfactory.'

If the inspector has indicated that an observation requires further investigation without delay, the person ordering this report is advised to arrange for the NICEIC contractor issuing the report (or another skilled person or persons competent in such work) to undertake further examination of that aspect of the installation as a matter of urgency, to determine whether or not danger or potential danger exists.

**Further information**

Further information on the application of Classification codes, primarily aimed at inspectors but of possible interest to persons ordering condition reports, can be found in Electrical Safety First's Best Practice Guide No 4 *Electrical installation condition reporting: Classification Codes for domestic and similar electrical installations*. The guide can be viewed or downloaded free of charge from [www.electricalsafetyfirst.org.uk](http://www.electricalsafetyfirst.org.uk)

For further information about electrical safety and how NICEIC can help you, visit  
[www.niceic.com](http://www.niceic.com)